

EC type examination certificate
EG-Baumusterprüfbescheinigung

CE-0085CL0441
 Product Identification No.
 Produkt-Identnummer

Field of Application <i>Anwendungsbereich</i>	EC Gas Appliances Directive (2009/142/EC) <i>EG-Gasgeräterichtlinie (2009/142/EG)</i>
Owner of Certificate <i>Zertifikatinhaber</i>	Ferrolì S.p.A. Via Ritonda 78A, I-37047 San Bonifacio (VR)
Distributor <i>Vertreiber</i>	Ferrolì S.p.A. Via Ritonda 78A, I-37047 San Bonifacio (VR)
Product Category <i>Produktart</i>	Boilers: Condensing water heater (3102)
Product Description <i>Produktbezeichnung</i>	Condensing boiler with fan-assisted burner in modulating operation method and with enclosed combustion chamber
Model <i>Modell</i>	Quadrifoglio...
Countries of Destination <i>Bestimmungsländer</i>	AT, BE, BG, BY, CH, CY, CZ, DE, DK, EE, ES, FI, FR, GB, GR, HR, HU, IE, IS, IT, LT, LU, LV, MT, NL, NO, PL, PT, RO, RU, SE, SI, SK, TR, UA
Test Reports <i>Prüfberichte</i>	supplement test: K10182013T1 from 07.07.2013 (TRG)
Test Basis <i>Prüfgrundlagen</i>	EU/2009/142/EG (30.11.2009) DIN EN 15502-1 (01.10.2012) DIN EN 15502-2/1 (01.01.2013)

File Number 13-0692-GER
Aktenzeichen

28.10.2013 Rie A-1/2
 Date, Issued by, Sheet, Head of Certification Body
 Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

DVGW CERT GmbH is an accredited body by DAkkS according to EN 45011:1998 and notified by the government of the Federal Republic of Germany for certification of gas appliances under EC Directive 2009/142/EC.

DVGW CERT GmbH ist von der DAkkS nach DIN EN 45011:1998 akkreditierte und von der Deutschen Bundesregierung benannte Stelle für die Zertifizierung von Gasgeräten gemäß EG-Richtlinie 2009/142/EG.



DVGW CERT GmbH
 Zertifizierungsstelle
 Josef-Wirmer-Str. 1-3
 53123 Bonn
 Tel. +49 228 91 88 - 888
 Fax +49 228 91 88 - 993
 www.dvgw-cert.com
 info@dvgw-cert.com

Electrical Data 230 V AC, 50 Hz
Elektrische Daten

Appliance Categories <i>Gerätekatogorien</i>	Supply Pressures <i>Versorgungsdrücke</i>	Countries of Destination <i>Bestimmungsländer</i>	Remarks <i>Bemerkungen</i>
I2E	20 mbar	LU	
I2ELw	20 mbar	PL	
I2H	20 mbar	LV	
I3B	28-30 mbar	ES, FR, GB, IE	
I3B	50 mbar	BE	
I3B/P	28-30 mbar	MT	
I3P	28-30 mbar	ES, FR, GB, IE	
I3P	37 mbar	BE, ES, FR, GB, IE	
I12E+3P	20/25, 28-30 mbar	FR	
I12E+3P	20/25, 37 mbar	BE, FR	
I12E+3P	20/25, 50 mbar	BE	
I12E3B/P	20, 28-30 mbar	PL	
I12ELL3B/P	20, 50 mbar	DE	
I12H3B/P	20, 28-30 mbar	FI, GR	
I12H3B/P	20, 30 mbar	CY, DK, EE, IS, IT, LT, NO, SE, SI, SK	
I12H3B/P	20, 37 mbar	CH, CZ, FI, GR, HR, IT, LT, TR	
I12H3B/P	20, 50 mbar	AT, CH, CY, CZ, HR, IS, SK	
I12H3P	20, 28-30 mbar	ES, GB, IE	
I12H3P	20, 30 mbar	PT, RO	
I12H3P	20, 37 mbar	ES, GB, IE	
I12H3P	20, 50 mbar	RO	
I12HS3B/P	20, 30 mbar	HU	
I12L3B/P	25, 30 mbar	NL	

Installation Codes <i>Installationsarten</i>	Countries of Destination <i>Bestimmungsländer</i>	Remarks <i>Bemerkungen</i>
B23	AT, BE, BG, BY, CH, CY, CZ, DE, DK, EE, ES, FI, FR, GB, GR, HR, HU, IE, IS, IT, LT, LU, LV, MT, NL, NO, PL, PT, RO, RU, SE, SI, SK, TR, UA	

Type <i>Typ</i>	Technical Data <i>Technische Daten</i>	Remarks <i>Bemerkungen</i>
Quadrifoglio B 70	nominal heat output: 13,7...64,4 kW nominal heat input (Hi): 14,0...65,5 kW	
Quadrifoglio B 125	nominal heat output: 22,5...114,0 kW nominal heat input (Hi): 23,0...116,0 kW	
Quadrifoglio B 220	nominal heat output: 40,2...204,0 kW nominal heat input (Hi): 41,0...207,0 kW	
Quadrifoglio B 320	nominal heat output: 60,8...294,5 kW nominal heat input (Hi): 62,0...299,0 kW	

Hints of Utilization /Remarks

Verwendungshinweise / Bemerkungen

Additional proved countries of destination, appliance categories and supply pressures:

UA: I2H (20 mbar)

BY, RU: I12H3B/P (20, 37 mbar)

BG, BY, RU: I12H3B/P (20, 50 mbar)

In Belarus, in the Russian Federation and in the Ukraine the CE-marking will be accepted as conformity approval if the Gas Appliance Directive (2009/142/EC) is transferred into national law by Belarus, Russian Federation respectively Ukraine.