



Product Service

Attestation of Conformity

No. D6 15 12 94556 001

**Holder of
Attestation:****GZ THEODOOR TECH CO.,LTD**No.1-63, Phoenix 3 Heng Road
Sino-Singapore Knowledge City , Luogang District
510555 Guangzhou
PEOPLE'S REPUBLIC OF CHINA**Product:****Heat pump
(Heat pump water heater)****Model(s):****RS-3.6FAD/190L; RS-3.6FAD/190LX9****Parameters:**Rated Voltage: 220-240 V
Rated Frequency: 50 Hz
Rated Power: 3,2 kW
Protection Class: Class I
Degree of Protection: IP X1
Refrigerant: R134a
Trank Volume: 190L
Implementation Measure EU Regulation
814/2013:2013-08-02
Stage 3 (26 September 2018)**Brand Name:****THEODOOR****Tested
according to:**

PPP 11114B:2015

This Attestation of Conformity is issued on a voluntary basis and confirms that the listed product fulfils the generic ecodesign requirements as stated in Annex I in combination with the specific ecodesign requirements defined in the above mentioned Implementation Measure and as stated in Annex II of Council Directive 2009/125/EC for the setting of ecodesign requirements for energy-related products. This attestation refers only to the sample submitted to TÜV SÜD PRODUCT SERVICE GMBH for testing and evaluation and to its technical documentation. See also notes overleaf.

Test report no.:

64181140125302

Date, 2015-12-29

(Gary Sun)



Page 1 of 1